

Attachment AD2.13

These drawings and specifications and the ideas, designs and arrangements represented thereby are and shall remain the property of KMM Services, Inc. and no part thereof shall be copied, disclosed to others, or used in connection with any other work or project other

Attachment AD2.14

GENERAL NOTES	
1)	NO STRUCTURAL ELEMENTS PENETRATED OR ALTERED
2)	PROVIDE APPROPRIATE WITNESS FITTINGS TO EXIT WITNESS TO TRANSITION DOWN TO DROP LOCATIONS
3)	RELOCATE EXISTING INTRUSION DEVICES UP OR DOWN TO ALLOW NEW RACEWAY TO BE INSTALLED. VERIFY THAT RELOCATED DEVICES IS NOT CAUSING A FAULT ON THE PANELS PRIOR TO SEALING THE SITES
4)	INSTALL DEDICATED 5/8" DIA. ELECTRICAL OUTLET INSTALLED INSIDE THE PANEL. (NET. ON INSIDE SIDE APPROX. 4")

SHEET NOTES	
-------------	--

3) SURFACE COATING AND SEALANT (SEE RACEWAY) REPLACE RACEWAY WITNESS (2300)

Attachment AD2.16

GENERAL NOTES	
1)	REMOVE DEVICES AND PRESERVE FOR REINSTALL
2)	VERIFY ADDRESSING WITH DISTRICT PRIOR TO REINSTALL

SHEET NOTES	
1)	REMOVE AND REINSTALL SMOKE DETECTOR
2)	REMOVE AND REINSTALL SPEAKER/STROBE
3)	INSTALL SMOKE DETECTOR ON ROOF DECK ABOVE TYPICAL CEILING WHEN REQUIRED SET TO NEXT AVAILABLE ADDRESS

