



4. Question: Fixtures in classroom 15 have been indicated that an abatement crew is needed to be contracted for their removal. Is abatement crew needed for installation of new fixtures in this classroom?

Response: Abatement contractor will be required for removal of old fixtures and attachment of new fixtures. Class in room 15 will be relocated for duration of work in room.

END OF ADDENDUM NO. 1